

Equipe SYREL-G2Elab

Lainser Sklab – Bertrand Raison

Impacts of Inverter Based Resources on Protections for distribution grids



Classical protection plan

Choice and settings of these protection relays:

If : $0,8 \times I_{scbi} > 1,2 \times I_{scTriG}$

- Non-directional OC

$$\max(1,3 \times I_p; 1,2 \times I_{scTriG}) \leq I_{s51} \leq 0,8 \times I_{scbi}$$

Else : $0,8 \times I_{scbi} \leq 1,2 \times I_{scTriG}$


- Non-directional OC:

$$1,2 \times I_{scTriG} \leq I_{s51}$$

- Directional OC:

$$1,3 \times I_p \leq I_{s67} \leq 0,8 \times I_{scbi}$$

The I_{scbi} , calculated according to the IEC 60909 standard, is the same whether the GCI is present or not, as their contribution is not taken into account!




Behaviour of IBR during a fault

Requirements from Distribution System Operators

The DSO formulates some requirements to allow the connection to its grid:

- To remain connected during a short period when a fault occurs (Low Voltage Ride Through (LVRT)).
- To inject reactive current during this period to support the voltage (Dynamic Voltage Support (DVS)).

Low Voltage Ride Through



A summary of several criteria for connecting PVPGS to the power grid


Country Grid Code (GC)	Rated Frequency (Hz)	Grid Frequency Boundries (Hz)	Maximum Allowed Time (Duration)	LVRT				HVRT	
				Within Fault		After Fault		During Voltage Swell	
				V1 (%)	t2 (s)	V2 (%)	t3 (s)	V (%)	t (s)
Germany GC	50	$f_g > 51.5$ $47.5 < f_g < 51.5$ $f_g < 47.5$	Disconnection (Trip) Stay in Operation (No Trip) Disconnection (Trip)	0	0.15	90	1.5	120	0.1
Italy GC	50	ND	ND	0	0.2	85	1.5	125	0.1
Spain GC	50	$f_g > 51.5$ $47.5 < f_g < 51.5$ $48 < f_g < 47.5$ $f_g < 47.5$	Disconnection (Trip) Stay in Operation (No Trip) 3 s Disconnection (Trip)	20	0.5	80	1.0	130	0.25
Australia GC	50	$f_g > 52$ $47.5 < f_g < 52$ $f_g < 47.5$	2 s Stay in Operation (No Trip) 2 s	0	0.45	80	0.45	130	0.06
China GC	50	$f_g > 50.2$ $49.5 < f_g < 50.2$ $48 < f_g < 49.5$ $f_g < 48$	2 min Stay in Operation (No Trip) 10 min Characteristics of PV Inverter	20	0.15	90	2	ND	ND
Malaysia GC	50	$f_g > 52$ $47 < f_g < 52$ $f_g < 47$	Disconnection (Trip) Stay in Operation (No Trip) Disconnection (Trip)	0	0.15	90	1.5	120	Continuous
South Africa GC	50	$f_g > 52$ $51 < f_g < 52$ $49 < f_g < 51$ $48 < f_g < 49$ $47 < f_g < 48$ $f_g < 47$	4 s 60 s Stay in Operation (No Trip) 60 s 10 s 0.2 s	0	0.15	85	2.0	120	0.15
Enedis	50			5	0.15	85	1.5		

Behaviour of IBR during a fault

Requirements from Distribution System Operators

Dynamic Voltage Support (DVS)

Country	$\Delta V_{\min 1}$ [pu]	$I_{q_{\min}}$ [pu]	$\Delta V_{\min 2}$ [pu]	$I_{q_{\max}}$ [pu]	ΔV_{\max} [pu]	k
Germany	-0.1	-0.2	-0.5	-1	0.1	2
Denmark	-0.1	0	-0.5	-1	0.1	2.5
China	-0.1	0	-0.8	-1.05	0.1	1.57
South Africa	-0.1	0	-0.5	-1	0.1	2.5




- The factor k influences the amount of reactive current that can be injected. For the countries we have studied, k ranges between 1.5 and 2.5.
- For most countries, the reactive current is saturated at 1 pu.

$$I_{cc_G} = I_{PQ} \quad [pu] \quad si: V_{ond1} > 0,85$$


$$I_{cc_G} = \sqrt{I_d^2 + I_q^2} = \begin{cases} I_q = k \cdot \Delta V / V_n \\ I_d = \sqrt{I_{\max}^2 - I_q^2} \end{cases} \quad [pu] \quad si: V_{ond1} \leq 0,85$$

Bad computation of the settings

Adjustment of protections according to the calculations of IEC 60909 standard.



IBR contributes to the fault



Non-directional OC relay settings range

Blinded Protection area


Equipe SYREL-G2Elab

Mamadou Salliou Diallo - Raphael Caire – Bertrand Raison


Impacts of Inverter Based Resources on Protections for transmission grids



How works a distance protection (PX)



Simulation studies



Transformer :

- ❑ $S_n = 75\text{MVA}$;
- ❑ $34,5/120\text{ kV}$;
- ❑ Couplage transfo : dY +30
- ❑ $Z_n = X_n = 38\Omega$;

HV line (PI model), $L = 50\text{km}$:

- ❑ $R_{1L} = 0,06\Omega/\text{km}$, $X_{1L} = 0,4\Omega/\text{km}$ et , $C_{1L} = 9,2\text{nF}/\text{km}$;
- ❑ $R_{0L} = 0,2\Omega/\text{km}$, $X_{0L} = 1,34\Omega/\text{km}$ et $C_{0L} = 5,2\text{nF}/\text{km}$.



Grid :

- ❑ $S_{cc} = 15906\text{ MVA}$;
- ❑ $X1/R1 = 17$;
- ❑ $U_n = 120\text{ kV}$



Note that the wind farm is at 90% of its maximum output at the time of the fault. This is an important point, as the level of production of the wind farm has an impact on the short-circuit current supplied by it during the fault. See the study report for more details.

AG short-circuit ($R_f=0\Omega$) - CSC

WP park




Grid




Test of commercial relays

Tests of 3 distance protection relays on AO3 offshore project of RTE.



Test of commercial relays

- ❑ Test of 3 distance protection relays on AO3 offshore project of RTE.



- ❑ 3 types of protection relays:

- ❑ 2 scenarios considered: **weak source** (short-circuit current **min : 19,78 kA**) and **strong source** (short-circuit current **max : 27,96 kA**).
- ❑ **150 various fault cases** (75 for weak source and 75 for strong source).

Synthesis of the tests

Relay 1	
Pour la source faible (Pcc min)	26,6%
Pour la source forte (Pcc max)	16,0%

Relay 2	
Pour la source faible (Pcc min)	29,3%
Pour la source forte (Pcc max)	21,3%

Relay 3	
Pour la source faible (Pcc min)	36,0%
Pour la source forte (Pcc max)	32,0%

$$\text{Trip ratio} = \frac{\text{Nb Trips}}{\text{Nb Faults}}$$

Nb Faults: number of faults to which the relay should normally trip

- ❑ **No tripping** for the 3 relays : from $R_F = 1 \Omega/\text{phase}$ (phase-to-phase faults).
- ❑ **No tripping** for the 3 relays : from $R_F = 9 \Omega$ (phase to ground faults).



**Thank you so much
for listning**